



PETRO-CANADA OIL AND GAS

**FIRE-TUBE IMMERSION HEATER
OPTIMIZATION PROGRAM**

&


Field Heater Audit Program



**Energy Management Work Shop
“The Fuel Gas Challenge”**

by **Phil Croteau P. Eng.**
Energy Efficiency Engineer

January 15-17, 2007





Outline (25 min session)



- Overview – Top 5 Priorities (PTAC – TEREЕ)
- PTAC – TEREЕ : the Origin of the “Fire-tube Heater Study”
- Combustion Efficiency. – Excess Air
- Heat Transfer – Fire-tube Design
- Combustion Efficiency – Fire-tube Selection
- Combustion Efficiency - Heat Flux Rate
- Burner Selection
- Burner Duty Cycle
- Combustion Efficiency – Reliability Guidelines
- Heater Tune-up – Inspection Procedure
- Insulation
- **PCOG Fire-tube Immersion Heater Optimization Program**
- **Field Audit Program (NRCAN Energy Audit Incentive Program)**
- Conclusion, Q&A



Overview: Top 5 Priorities, ER & EE



PTAC - TERE Study 2004-2005: Top 5 Priorities for ER and EE

Petroleum **T**echnology **A**lliance **C**anada

– **T**echnology for **E**mission **R**eduction and **E**co-**E**fficiency

1. Venting of Methane Emissions
2. Fuel Consumption in Reciprocating Engines
- 3. Fuel Consumption in Fired Heaters*
4. Flaring and Incineration
5. Fugitive Emissions



Background



- Common concern for many upstream operating companies is the energy consumption associated with **immersion heaters**
- Energy often used to fire these heaters is high quality refined sales gas
- Common problem with the immersion heaters is that they may have low fuel efficiencies between 30% and 60%
- Compared to common boiler technology these heaters should be able to run at 70 to 80% efficiency
- Recent estimates suggest that heaters currently waste in excess of 2 to 3 billion BTU/hr of fuel (1360 to 2040 e3m3/d gas) that could be conserved to generate added sales
- At an average cost of \$5/GJ this represents \$100 to \$150 million of lost revenues due to inefficient use of fuel gas
- Also represents an associated 1.5 million additional tonnes of carbon dioxide being discharged into the atmosphere per year



Project Sponsors



The following sponsors collaborated with PTAC to provide financial and technical support:

Petro-Canada

Shell Canada

EnCana Corporation

CETAC-West

Husky Energy

CAPP

Nexen

BP Canada


The report has now been publicly released, and is available to view on the PTAC website at

www.ptac.org/techeetteree.html







PTAC Fire-tube Heater Study



- We built a heater, fired it with several different burners!



PTAC Lineheater Study



Fired as 2-3-4
passes

The image shows a complex industrial setup for a PTAC lineheater study. A large, horizontal, cylindrical stainless steel vessel is the central component, connected to a network of pipes and valves. A blue barrel is positioned in the foreground, and a vertical stack of pipes is visible in the background. The setup is located outdoors on a gravel surface next to a building. Two inset images provide close-up views of the piping and measurement equipment.

Primary Air
Measurement



Burner Vendors Participating

- A-Fire
- ACL
- Bekaert (MCI) (3)
7 combinations
- Eclipse
- Hauck
- Kenilworth (4)
- Maxon (3)
- North American
- Pro-Fire (2)
- Pyronics (4)





10 burner vendors = 25 burners tested

TESTS – OPEN FLAME TESTS



HEATER TEST STAND - INSTRUMENTATION



DCS control and data recording

Heat Transfer


PTAC Test – Glycol, 2-3-4 passes

- Fire-tube Design

IMPROVED FIRE-TUBE IMMERSION HEATER EFFICIENCY PROJECT - EETR 0401



Tube Temperature Profiles with Water - Gas Side - Hauck Burner at 500,000 BTU/hr HHV fuel input





Combustion Efficiency – Excess Air

The GOOD, the BAD & the UGLY!




IMPROVED FIRE-TUBE IMMERSION HEATER EFFICIENCY PROJECT - CEIR 9401





HEATER HHV EFFICIENCY OPERATING AREAS

Based on Fuel = Natural Gas as Methane (CH₄) 89120 Btu/lb HHV



Design by: SUEP-EN Energy Efficiency Engineering Ltd

Combustion Air Control



Excess air baffles!





As found: fouled flame cell!



Excess air 0.0%

Stack CO >110,000 ppm !

Flame cells are not filters!

Excess Air/O₂ Control






COMBUSTION EFFICIENCY - IMPACTED BY FIRE-TUBE SELECTION (SENSIBLE HEAT RECOVERY!)

IMPROVED FIRE-TUBE IMMERSION HEATER EFFICIENCY PROJECT - EETR 0401



PETROLEUM
TECHNOLOGY
ALLIANCE
CANADA



COMBUSTION EFFICIENCY - IMPACTED BY FIRE-TUBE HEAT FLUX RATE

IMPROVED FIRE-TUBE IMMERSION HEATER EFFICIENCY PROJECT - EETR-9481




Average Surface Heat Flux Charts
for 4" to 36" 2 Pass Fire Tubes

Based on: Fuel = Natural Gas at Heating Value (HHV) 1075 Btu/ft³, 20 ft stack,
Ambient Temp = 50 deg C (summer case), Gas Temp = 80 deg C (design case);
Cleveland ASU = 2.14 m²/sq ft (Alberk), Stack CO = 2.5% (12.1% excess air)

~ 76 %

~ 69%







Design by: OnOffEnergy Efficiency Engineering Ltd

Burner Selection

- HIGH PRIMARY AIR INSPIRATION, TURNDOWN, FUNCTIONALITY
- MAXON VENTITE

 PETROLEUM TECHNOLOGY ALLIANCE CANADA		IMPROVED FIRE-TUBE IMMERSION HEATER EFFICIENCY PROJECT Project EETR 0401 Burner Characteristics Design by: ENEFEN Energy Efficiency Engineering Ltd.	
Manufacturer:	Maxon Large	Address:	6375 Dixie Road, Unit 3
Description:	3" Ventite	City, Province, Code:	Mississauga, ON L5T 2E1
Orifice:	1/8"	Telephone / Fax:	(905) 795-0717/(905) 795-1819
Overall Length:	21"	Web Site:	http://www.maxoncorp.com
		General Arrangement Compact burner assembly features gas nozzle, venturi, mixer, and primary air shutter combination. Heavy duty cast iron components	
		Gas Nozzle Heavy duty cast iron nozzle includes internal flame retention device with large main gas orifice and 8 smaller holes located around its perimeter. Available with integral pilot and flame rod mount (PilotPak).	
		Gas Mixer & Primary Air Adjustment Gas mixer features a low entrance loss bell shaped inlet. Heavy duty cast iron "register" type shutter includes a locking screw. Gas Connection through the back of the mixer. Simple rear access to the orifice by unbolting the back plate of the register.	
		Secondary Air Adjustment No secondary air adjustment incorporated	

 PETROLEUM TECHNOLOGY ALLIANCE CANADA		IMPROVED FIRE-TUBE IMMERSION HEATER EFFICIENCY PROJECT Project EETR 0401 Burner Open Flame Tests Design by: ENEFEN Energy Efficiency Engineering Ltd.	
Manufacturer:	Maxon Large		
Description:	3" Ventite		
Orifice:	1/8"		
Date:	16-Mar-05		
			
524,000 BTU/hr ; 100%		304,000 BTU/hr ; 100%	
			
		148,000 BTU/hr ; 100%	
			
531,000 BTU/hr ; 50%		295,000 BTU/hr ; 50%	
			
		118,000 BTU/hr ; 50%	
			
530,000 BTU/hr ; 28%		289,000 BTU/hr ; 28%	
			
		117,000 BTU/hr ; 28%	
			
531,000 BTU/hr ; 10%		290,000 BTU/hr ; 10%	

BURNER SELECTION




- ECLIPSE

 PETROLEUM TECHNOLOGY ALLIANCE CANADA		IMPROVED FIRE-TUBE IMMERSION HEATER EFFICIENCY PROJECT Project EETR 0401 Burner Characteristics Design by: ENEFEN Energy Efficiency Engineering Ltd.	
Manufacturer:	Eclipse	Address:	#5,3530-11A Street N.E.
Description:	1-1/2" Eclipse Mixer, With 1-1/2" Compound Barrel, 1-1/2" x 2-1/2" Venturi, 2-1/2" Nozzle	City, Province, Code:	Calgary, AB T2E 6M7
Orifice:	1/8"	Telephone / Fax:	(403) 291-9211/(403) 291-9214
Overall Length:	30"	Web Site:	www.eclipsenet.com
		General Arrangement Typical complete assembly of Eclipse burner common in the industry. Assembly consists of a mixer, compound barrel, Venturi, and gas nozzle.	
		Gas Nozzle Eclipse Ferrox Nozzle with built-in flame retention feature. Nozzle produces long and narrow flame pattern as compared to a wider flame available with Sticktite nozzles.	
		Gas Mixer & Primary Air Adjustment Eclipse mixer commonly used in the industry also by some of the other burner manufacturers. Basic mixer features cast iron body with gas orifice and primary air shutter. Also supplied with the burner is a needle valve which allows fine adjustment to the orifice opening. The optional compound barrel is used to enhance fuel/air mixing, and is recommended for heavier fuel gases.	
		Secondary Air Adjustment No secondary air adjustment incorporated	

 PETROLEUM TECHNOLOGY ALLIANCE CANADA		IMPROVED FIRE-TUBE IMMERSION HEATER EFFICIENCY PROJECT Project EETR 0401 Burner Open Flame Tests Design by: ENEFEN Energy Efficiency Engineering Ltd.	
Manufacturer:	Eclipse		
Description:	1-1/2" Eclipse Mixer, With 1-1/2" Compound Barrel, 1-1/2" x 2-1/2" Venturi, 2-1/2" Nozzle		
Orifice:	1/8"		
Date:	14-Mar-05		
			
496,000 BTU/hr ; 100% open		353,000 BTU/hr ; 100% open	
			
497,000 BTU/hr ; 2 turns		212,000 BTU/hr ; 2 turns	
			
497,000 BTU/hr ; 0.5 turns		320,000 BTU/hr ; 0.5 turns	
			
497,000 BTU/hr ; 0.5 turns		198,000 BTU/hr ; 0.5 turns	
			


BURNER SELECTION

- HIGH PRIMARY AIR INSPIRATION,
- TURNDOWN,
- FUNCTIONALITY



Burner Duty Cycle Management

- short duty cycle at high firing rate vs. the longer duty cycle firing at a lower rate



Duty Cycle to the Extreme - This is the consequence of an **extremely low main burner duty cycle**, only the pilot ran, **condensing moisture in "Products of Combustion"**. Water accumulates and freezes at the flame cell as it tries to drain out. Level rises until even the pilot is extinguished! This is a concern for oversized heaters, more common a problem than we accept.



Combustion Efficiency, Emission and Reliability Guidelines 4 Pages

IMMERSION HEATER FIELD INSPECTION AND EFFICIENCY EVALUATION REPORT	 <p>PETROLEUM TECHNOLOGY ALLIANCE CANADA</p> <p>Design by: ENEFEN Energy Efficiency Engineering Ltd.</p>
COMBUSTION EFFICIENCY, EMISSIONS AND RELIABILITY GUIDELINES	
1	<p>EFFICIENCY DEFINITION: Efficiency is defined as the percentage of gross BTU input that is realized as useful BTU output of a heater. There are two ways of calculating this efficiency: the HHV efficiency uses the higher heating value of fuel input, and the LHV efficiency uses lower heating value of fuel input.</p>
2	<p>LHV AND HHV BASED EFFICIENCY CALCULATIONS For example pure methane HHV = 1012 BTU/cuft and LHV = 911 BTU/cuft, and the difference is the amount of energy used to evaporate water produced during the combustion process from the hydrogen contained in the fuel. Hence for the same combustion process using methane as a fuel the LHV efficiency value is about 10% higher than the HHV efficiency value. Where the LHV efficiency is easier to use for evaluation of traditional style heaters which do not condense water out of the products of combustion, it cannot be meaningfully used for newer condensing type heaters. In addition, since fuel is measured and sold based on its HHV value, only the HHV based efficiency should be used for the economic evaluation of the heater performance. LHV based efficiency is typically used in the US and the HHV efficiency is more commonly used in Canada. All regulatory requirements in Canada related to burner and fuel controls rating are based on HHV of fuel. Since many heater specifications and many combustion analyzers do not clearly state the basis for efficiency calculations, caution should be exercised when using these efficiency values.</p>
3	<p>COMBUSTION EFFICIENCY - OVERALL COMBUSTION EFFICIENCY - FUEL EFFICIENCY - HEATER THERMAL EFFICIENCY: These terms are used in the industry interchangeably, although with a fair amount of confusion. To clarify: any of these efficiency terms is based on the calculation of 100% of energy input into the heater (expressed in either LHV or HHV terms) <u>minus</u> the summation of all the losses from that heater, which <u>equals to</u> the useful heat output to the process load. The losses can be either combustion related or heater design specific.</p>
4	<p>COMBUSTION LOSSES FROM THE HEATER: These losses include:</p> <ul style="list-style-type: none"> - latent heat of evaporation to moisture in the stack formed from oxidation of hydrogen in the fuel - unburned fuel (VOC's in the stack) including hydrocarbons, CO, soot (free carbon), H₂S or any other combustible compound which did not get oxidized to form CO₂ or H₂O - sensible heat lost to heat the product of combustion above the ambient air temperature. Products of combustion include also nitrogen, excess oxygen and H₂O vapour from ambient air humidity and possibly the unburned fuel which do not take part in the combustion process but are also heated to the stack temperature. Note that besides combustion air, ambient tramp air can also infiltrate the heater through cracks and openings, however that tramp air would be then included in the products of combustion.
5	<p>HEATER DESIGN SPECIFIC LOSSES: These losses include:</p> <ul style="list-style-type: none"> - wall / piping / insulation losses - the energy which radiates out of the heater into the surroundings and is carried away by air (wind), foundations, or connecting equipment. Note that only the heat loss from the portion of the stack surface below the location of the thermocouple used for the efficiency measurement would be considered as a loss for this calculation. - opening losses include any products of combustion leaks from the heater other than stack gas. - conveyor losses include heat carried away by any form of process "conveyor" which does not stay in the process "product". This would also include heat loss through the piping connecting process to the heater. - heat storage losses - the energy which is stored in the heater steel, insulation, heat transfer medium, connected equipment, foundation, etc. For heaters, which operate continuously the amount of stored energy remains constant after the initial heatup. For heaters which operate in batch mode or which cycle on/off, the amount of stored heat changes and must be replenished every time the heater is refilled and restarted.
6	<p>STACK OXYGEN: Stack oxygen level should be maintained between 2% and 4%, which corresponds to between 9.5% and 21.1% excess air. Below 2% oxygen, sharp increase in CO emissions is expected; above 4% oxygen additional excess air "taking a free ride" through the heater decreases the combustion efficiency</p>
7	<p>STACK CO: Stack CO levels should be maintained below 400 ppm safety ceiling. Ideally, in a properly tuned system CO levels below 100 are desirable. Typically, depending on the burner design, CO readings increase at low (below 2%) or high (above 11%) oxygen levels. High CO readings indicate incomplete combustion due to insufficient air flow or due to flame quenching with too much air.</p>
8	<p>STACK NOx: Stack NOx levels are a function of burner design and specifically flame shape and temperature. Smaller and hotter flames tend to produce higher NOx levels. Also burners with a single fuel injection port tend to produce higher NOx levels than those with multiple smaller and spread out ports (fuel staging effect). Typically, properly designed natural draft burners produce between 60 ppm and 80 ppm corrected to 3% oxygen (V/V dry basis) in the stack. Within a given burner design NOx formation is pretty well fixed and cannot be changed by regular tune up techniques.</p>


Heater Tune-up / Inspection Procedure

2 Pages

IMMERSION HEATER FIELD INSPECTION AND EFFICIENCY EVALUATION REPORT		 PTAC <small>Design by: ENEFEN Energy Efficiency Engineering Ltd</small>	PETROLEUM TECHNOLOGY ALLIANCE CANADA
HEATER TUNE UP / INSPECTION PROCEDURE			
1	Gas Leak Test: Check area around the heater and inside the fuel train or control enclosure (if present) for safe H ₂ S, O ₂ and LEL levels		
2	Visual Inspection: Inspect heater for obvious signs of deterioration, corrosion, damage to instrumentation or fuel train components		
3	Pilot observation: Check if heater main burner is firing. If not, check if the pilot is on. If pilot is not on check if the fuel to the pilot is turned on and if so turn the pilot fuel off and wait a few minutes for the fire tube to ventilate. Check with the control room if there is any reason why the heater is turned off. Once safe to do so, turn the main burner manual fuel valve off, relight the pilot and observe. The pilot should be at least 4" to 8" in length, if smaller, try to increase fuel flow to pilot until "solid" pilot is established.		
4	Record Heater Data: Record heater data such as make, model, year built, serial number, design process duty, burner type and size, burner orifice size, fire tube OD and length, stack OD and height, etc. as per enclosed inspection and evaluation report sheet.		
5	Main flame observation: Check all heater permissives such as liquid level L.O, temperature HI shutdown, bath temperature setpoint. If everything is OK, open the main burner manual valve. Observe main flame shape, colour, stability, anchoring, noise, impingement on the tube surface.		
6	Fuel Pressure Measurement: Measure and record fuel gas supply pressure, and main burner pressure (after regulation) while it is firing.		
7	Fuel Flow Measurement: If available measure fuel gas flow to the main burner by timing the gas meter or measuring pressure drop across the fuel metering orifice. Another simple method is the measurement of the burner gas orifice size and calculation of the gas flow using orifice pressure drop charts. Since the mixture pressure inside the burner Venturi is typically negligible compared to the burner inlet pressure, the burner inlet pressure can be used as an approximation of the pressure drop in the charts. Note, that this method cannot be utilized if the fuel gas orifice is used in conjunction with an adjusting needle valve as it is often the case with Eclipse mixers.		
8	Heater bath temperature check: Locate bath temperature gauge and record bath temperature. Record also the temperature control setpoint of the temperature controller.		
9	Stack Measurements: Locate sampling port in the straight length of stack above the fire tube exit from the heater. If no port is available, drill and tap 3/8"UNC hole in the stack. Using combustion analyzer take reading of: Flue Temperature, O ₂ , CO, NO _x and efficiency. Record also the ambient air temperature. After taking the sample install a 3/8" bolt using high temperature anti-seize compound or a brass bolt.		
10	HI CO / LOW O₂ with air passages closed: If CO reading is high (in thousands of ppm) and O ₂ reading very low (close to zero), the heater is being fired substoichiometrically without sufficient oxygen. Remove sample probe from the stack immediately to prevent damaging the CO analyzer cell. Let analyzer purge the cell until CO reading drops to zero. Open access port in the flame arrestor to allow more air flow. Insert analyzer probe back into the stack and observe CO readings. If readings have improved, with the access port open, there is a good possibility that the flame cell is plugged up and needs cleaning. Check also position of any secondary air control devices to make sure that they are not blocking the air flow into the burner.		
11	HI CO / LOW O₂ with air passages open. Burner primary air is misadjusted and must be opened. Open slowly watching the analyzer CO readings until CO levels are low. If there is no or slow reaction, reduce fuel gas pressure to main burner gradually also watching for changes in CO. On some burner models (Eclipse) there could be also a fuel needle valve present which could be adjusted. Note that overfiring of the heater without sufficient combustion air does not increase the heat transfer and it may even decrease it through tube sooting or decrease in the flame temperature. It is also unsafe and may lead to a premature heater failure.		
12	HI CO / HIGH O₂ The indication is that there is too much combustion air. Reduce the primary and secondary air down to 3 to 4% oxygen in the stack.		

Insulation Heat Loss from Vessel Shell

- reduction in lost heat (demand) is a 100% saving, adjustments to appliance efficiency, etc. is only partial





PCOG Fire-tube Immersion Heater Optimization Program



PETRO-CANADA OIL AND GAS




FIRE-TUBE IMMERSION HEATER OPTIMIZATION PROGRAM

"When you can measure what you are speaking about, and express it in numbers; you know something about it, when you cannot express it in numbers, your knowledge is of a meager and unsatisfactory kind."
Lord Kelvin (1801)

"If you cannot measure it, you cannot improve it."
Lord Kelvin (1805)

"You cannot manage what you do not measure."
Commonly used today!

FR
FL
FT



"You cannot manage what you do not measure."

Philip J. Croteau - P.Eng.
Gerald Hewitt - Operations
Harley Siebold - Operations
Rev. Mar 27, 2006
DRAFT



Essential Elements of a Heater Optimization Program



Executive Summary

- quantify your number of heaters
- identify/understand their service
- quantify how much fuel they are thought to consume
- make assumptions of their current efficiency
- identify the potential efficiency target and savings
- identify how to get there

Statement of Commitment

- Body of the Program Document

Conclusions

**TRAINING, AUDITING, MAINTENANCE
& TAKING ACTION TO IMPROVE!**



Overview: Fire-tube Heater Survey



Just how many fire-tube heaters do we/you fire!

- *Following is an ~ count of both PCOG and third party. If we don't steward the third party heaters, who will.*
- *Do we/you have heaters operated by third party?*

195	FR – Reboilers: Amine, Glycol ...
510	FL – Lineheaters: Glycol, Salt Bath ...
11	FT - Treaters
716	

Target is to audit 1/3 of heaters per year on 3 yr rotation.



PCOG Statement of Commitment



- excerpt from "Fire-tube Immersion Heater Optimization Program"


Statement of Commitment:

Through our TLM program, Petro-Canada focuses on improvements in the elements of **safety, environment, reliability, economics and the general management** of our facilities.



As one of the areas of focus, Petro-Canada had recently committed resources and funding to participate in a study to review and improve our understanding in the **design and operation of fire-tube immersion heaters** and follow-up with implementation to optimize that equipment. Management is committed to improving the performance of these heaters through expectations of support from **Operations, Maintenance and Engineering (OME)**.

Heat Transfer

- Fire-tube Design



Duty Cycle



Combustion Analysis

- 3 T's plus Excess O₂


Time - Temperature - Turbulence

+ Excess O₂: approx. 3%


Time at Temperature

"NEW" addition of the 4th T - Training!

Burner Selection




FIRE-TUBE IMMERSION HEATER DESIGN & OPERATION



Long and Skinny Fire-tube to Improve Heat Transfer

Sept 2006 test heater built, **Wildcat Hills Choke Heater**
6' was added to standard fire-tube Flux = 7,000 Btu/hrft²



1 mm Btu/hr process duty

- Longer, more slender fire-tube is not new, many older heaters were built this way and exhibited better efficiency!

Vendor made the fire-tube, shell and process coils longer (with fewer return bends, lowering coil press drop!), shell dia. finished smaller.

Fabricated cost of steel ended up similar to standard design.




PCOG Fire-tube Heater Field Audits



- Petro-Canada is actively participating in **10 applications** pursuing fire-tube heater efficiency improvements.
- Assisted by the NRCAN audit process we are attempting to assess 1/3 of our heater fleet/yr. on an ongoing cycle.

NRCAN Industrial Energy Audit Incentive Program

This incentive is designed to help defray the cost of hiring a professional energy auditor to conduct an on-site [audit](#) at an industrial facility.



Natural Resources
Canada

Ressources naturelles
Canada





Fire-tube Heater "Field Audit" Program



		ENEFE Energy Efficiency Engineering Ltd. #307 - 4806 47th Avenue, Leduc, AB, T9E 5X3, Canada	
Alberta TEL: (780) 940-3464		Contact: Jozef Jachniak, P.Eng.	
BC TEL: (604) 808-1974		jjachniak@enefen.com	
FAX: 1-866-583-0520		www.enefen.com	
EFFICIENCYGRAM™ IMMERSION FIRE-TUBE HEATER PERFORMANCE EVALUATION REPORT			
<small>This report is based on and contains proprietary technology, measurement techniques and information, which are the intellectual property of ENEFEN Energy Efficiency Engineering Ltd. It is intended for the sole use of the primary addressee. The information contained in this report is private and confidential and copying, forwarding or other dissemination or distribution of this information by any means without an explicit permission from ENEFEN is prohibited.</small>			
Report by:	Report Date:	Report No.:	
Jozef Jachniak, P.Eng.	4-Oct-06	EG-0610002	
CUSTOMER DATA			
Client:	Petro Canada Oil and Gas		
Plant:	Wildcat Hills Gas Plant		
Area:	Viking Field		
LSD:	05-13-28-07-W5		
Contact:	Phil Croteau		
Phone Number:	403-296-5977		
Date:	4-Oct-06		

HEATER TREND DATA



- Stack temp and fuel gas pressure to burner orifice are key variables!

Heater Utilization – New Equip Performance Validation, in this case heater was only firing 31% duty at < 1/3 design firing rate. Only 10% design utilization, not ideal for a new heater!

NFN	ENEFF Energy Efficiency Engineering Ltd	
	Report By:	Jozef Jachniak, P.Eng.
	Report Date:	4-Oct-06
	Report No.:	EG-0610002

DATA KIT HEATER PERFORMANCE TRENDRNG Cont'd			
Measured Fuel Flows			
Total Fuel Consumed During Test	SCF	2154.6	
Fuel wasted below BST pressure	SCF	0.9	BST = Burner Stability Threshold
Fuel Used Effectively for heating	SCF	6833.3	Based on effective efficiency calculation
% Wasted Fuel	%	0.0%	
Maximum Fuel Flow	SCFH	482.8	
Average Fuel Flow During ON TIME	SCFH	438.7	
Average Fuel Flow before BST	SCFH	112.7	
Constant Equivalent Fuel Flow	SCFH	196.3	
Constant Pilot Fuel Flow (nominal)	SCFH	33.0	
Constant Total Fuel Flow	SCFH	166.3	

THERMAL PERFORMANCE			
Current Peak Condition			
Fuel Peak Input incl. pilot	MM BTU/hr	0.49	
Process Peak Heat Input	MM BTU/hr	0.40	
Fire-Tube Surface Heat Flux Rate	BTU/hr/ft ²	2.131	
Cross-sectional Heat Flux	BTU/hr/in ²	2.826	
Equivalent Continuous Flow			
Constant Equivalent Fuel Input	MM BTU/hr	0.17	
Process Heat Requirement	MM BTU/hr	0.13	
Fire-Tube Surface Heat Flux Rate	BTU/hr/ft ²	691	
Cross-sectional Heat Flux	BTU/hr/in ²	904	
Fire-Tube Rating			
Maximum plate rating (per tube)	MM BTU/hr	1.50	
Original rating based on 10% heat flux	MM BTU/hr	1.30	Heater designed for 7000 BTU/hr/ft ² heat flux
Utilization of Original Rating	%	6.8%	9.7% based on 7000 BTU/hr/ft ² heat flux

BURNER SIZING ANALYSIS			
Existing Burner Configuration			
Extra Burner Capacity	MM BTU/hr	0.03	
Total Required Fuel Input	MM BTU/hr	0.21	
Less pilot capacity	MM BTU/hr	0.03	
Main Burner Fuel Input	MM BTU/hr	0.15	
Existing Burner			
Number of burners per fire-tube		1	
Existing Burner Size	in	4	
Revised burner sizing - single burner installation			
Fire-Tube Size	in	14	
Maximum allowable burner size	in	4	Limited by fire-tube diameter
Burner size to meet capacity	in	1.5	Burner size less than maximum
Maximum nominal burner capacity	BTU/hr	212,500	
Minimum nominal burner capacity	BTU/hr	53,150	
% Maximum Burner Fire	%	83.90	
Non-leak maximum burner pressure	psig	20.00	
Orifice size required	in	0.0746	
Closest Drill #	#	#60	
Drill Diameter	in	0.0760	

NFN	ENEFF Energy Efficiency Engineering Ltd	
	Report By:	Jozef Jachniak, P.Eng.
	Report Date:	4-Oct-06
	Report No.:	EG-0610002

UPGRADE RECOMMENDATIONS		
Urgency of upgrades: 3 = High, 2 = medium, 1 = low		
Process Improvements		
1.1 Target Efficiency (% HHV)	85.5	Based on optimized burner size & setup
1.2 Review Process Requirements	3	Gross mismatch between firing rate & process demand
1.3 Lower Burner Temperature		
1.4 Shut heater off when not needed		
1.5 Review temp. sensor location		
1.6 Review external heat losses		
1.7 Repeat data logging		
1.8 Repeat stack analysis		
1.9 Other process improvement		
Maintenance Improvements		
2.1 Clean flame cell		
2.2 Clean fire-tube		
2.3 Fix fire-tube		
2.4 Adjust combustion air		
2.5 Adjust fuel gas pressure		
2.6 Clean burner		
2.7 Clean pilot		
2.8 Set up control loop		
2.9 Test flame arrester		
2.10 Other maintenance improvement		
Minor Modifications		
3.1 Add / modify secondary air plate	3	Necessary to control excess air
3.2 Replace burner	3	Improper burner size, arrangement or condition
3.3 Replace pilot		
3.4 Align burner		
3.5 Align pilot		
3.6 Change burner orifice		
3.7 Remove burner adjusting needle		
3.8 Add view port		
3.9 Replace flame cell		
3.10 Install burner union		
3.11 Install housing couplings		
3.12 Install wiring seal on airbox		
3.13 Change regulator spring		
3.14 Change regulator orifice		
3.15 Replace pressure gauges		
3.16 Change TSH / TSH to snap acting		
3.17 Other minor modification		
Major Modifications		
4.1 Install / replace IHH (ignition flame detector)		
4.2 Install power source		
4.3 Modify to inter-ignite pilot		
4.4 Add / replace safety shutoff valve(s)		
4.5 Add / replace manual valve(s)		
4.6 Add / replace LCLL		
4.7 Add / replace TSH / TSH		
4.8 Add fuel gas PSHH / PCLL		
4.9 Address other safety issue		

Opportunity to save capital building heaters smarter, smaller!

Summary Sheet of Expected Savings

		ENEFCN Energy Efficiency Engineering Ltd.	
		Report By:	Jozef Jachniak, P.Eng.
		Report Date:	4-Oct-06
		Report No.:	EG-0613062
UPGRADE RECOMMENDATIONS		Urgency of upgrades: 2 = high 2 = medium 1 = low	
Major modifications (only if)			
4.10 Add H/LC/OFF control			
4.11 Add modulating control			
4.12 Upgrade venting system			
4.13 Change pressure regulator(s)			
4.14 Modify instrument gas system			
4.15 Replace burner housing			
4.16 Insulate heater			
4.17 Insulate stack			
4.18 Add stack height			
4.19 Add stack thermometer			
4.20 Replace fire-tube			
4.21 Add lightning / view port to fire tube			
4.22 Other major modification			
ESTIMATE OF SAVINGS			
Measured Constant Total Fuel Flow	SCFH	155.3	
Seasonal Fuel Flow Correction	%	25.00	To compensate for winter demand
Annual Fuel Consumption	SCF	1,820,698	Based on 8760 hrs/yr operation
(Based on constant 1000 BTU / SCF Btu)	m ³	81,563	constant total fuel flow
	MV BTU	1821	
	GJ	1921	
Effective Efficiency	%	82.16	
Achievable efficiency	%	85.46	
Improvement in efficiency	%	3.30	
	%	3.98	
Annual Fuel Savings Due to Efficiency Improvement	SCF	70,276	
	m ³	1,950	
	MV BTU	70	
	GJ	74	
	SCF	154	
Annual Fuel Savings Due to Elimination of Fuel Pressures below BST	m ³	5	
	MV BTU	0	
	GJ	0	
	SCF	70,440	
Total Annual Fuel Savings	m ³	1,955	
	MV BTU	70	
	GJ	74	
Annual CO ₂ Emission Reduction	tons/year	3.7	



Conclusion



The means to achieve improved efficiency is as simple as:

- **training** – theory, operations, combustion testing with analyzer, CMMS (EMPAC)
- manage **excess air** in combustion
- manage the burner **duty cycle**
- strive for 82% **combustion efficiency** (depends on service, i.e. bath approach temp)
- provide adequate **insulation** to reduce energy demand (reduction is a 100% improvement)
- steward regular **combustion analysis** and **inspection** of heaters spring and fall, focusing on duty cycles, CO in combustion, excess air and stack temperature (fire-tube exit temp)
- **integrate** burner duty with **process demand** where possible
- **design** new equipment to address the items above (burners and fire-tubes)
- maintain **CMMS records** of fired equipment
- **DESIGN YOUR HEATER TO MEET THE SERVICE – DUTY, FIRING MODE, ENGAGE (OME), PRODUCTION AND PROJECT GROUPS!**